

Attestation of Conformity

Attestation No: SHA-AoC-230009

Applicant Name & Address: Afore New Energy Technology (Shanghai) Co., Ltd.
Building 7, No.333 Wanfang Rd, Minhang District, Shanghai. China.
201112

Factory Name & Address: Afore New Energy Technology (Shanghai) Co., Ltd.
Building 7, No.333 Wanfang Rd, Minhang District, Shanghai. China.
201112

Product Description: PV Grid interactive inverter

Brand Name: Afore

Model: BNT003KTA, BNT004KTA, BNT005KTA, BNT006KTA, BNT008KTA,
BNT010KTA, BNT012KTA, BNT015KTA, BNT003KTL, BNT004KTL,
BNT005KTL, BNT006KTL, BNT008KTL, BNT010KTL, BNT012KTL,
BNT013KTL, BNT015KTL, BNT017KTL, BNT020KTL, BNT025KTL

Characteristics: See appendix for details

Standards: EN 62109-1:2010; EN 62109-2:2011

EU Directive: Low Voltage Directive (LVD) (2014/35/EU)

Test Report No: 230601219SHA-001, 230601219SHA-002

Issued by: Intertek Testing Services Ltd. Shanghai

Issue date: 2023-07-19

This is to attest that the Technical Construction File for the product listed above has been evaluated against the Essential Safety Requirements of Annex I of The Low Voltage Directive (2014/35/EU). This Attestation can be used in support of the Manufacturers Declaration of Conformity on affixing the CE mark. Product conformity to CE marking is not assured until all other applicable EU Regulations are met in full.


Signature

Name: Qiao Qiao



APPENDIX: Attestation of Conformity

Ratings & Principle Characteristics:

Specifications table				
Model	BNT003KTA	BNT004KTA	BNT005KTA	BNT006KTA
PV input				
P _{pv} Max(W)	5100	6000	7500	9000
V _{max} PV (Vdc) (absolute Max.)	750	750	750	750
I _{sc} PV (absolute Max.) (A)	25x 2	25x 2	25x 2	25x 2
Number MPP trackers	2	2	2	2
Number input strings	1/1	1/1	1/1	1/1
Max. PV input current (A)	15 x 2	15 x 2	15 x 2	15 x 2
MPPT voltage range (Vdc)	150-600	150-600	150-600	150-600
Vdc range @ full power (Vdc)	220-600	220-600	220-600	220-600
AC Grid (output)				
Normal AC Voltage (VAC)	3P+PE/3P 133/230			
Frequency (Hz)	50			
Normal AC Current (A)	7.6	10.1	12.6	15.1
Max. cont. output current (A)	10.5	13.5	17.0	21.5
Normal Power (W)	3000	4000	5000	6000
Rated Apparent Power (VA)	3000	4000	5000	6000
Max. cont. Power (W)	3000	4000	5000	6000
Max. cont. Apparent Power (VA)	3000	4000	5000	6000
Power factor(adjustable)	1.0(-0.8~ +0.8)			
Others				
Protective class	Class I			
Ingress protection (IP)	IP65			
Temperature (°C)	-25°C to +60°C (Derating 45°C)			
Inverter Isolation	Non-isolated			
Overvoltage category	OVC III (AC Main), OVC II (PV)			
Software version	DSP:V06 CPLD:V06 HMI:V06			

This Attestation is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Attestation. Only the Client is authorized to permit copying or distribution of this Attestation.. The observations and test/inspection results referenced in this Attestation are relevant only to the sample tested/inspected. This Attestation by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program. This Attestation is not accredited under a ISO IEC 17065 accreditation.

APPENDIX: Attestation of Conformity

Ratings & Principle Characteristics:

Specifications table				
Model	BNT008KTA	BNT010KTA	BNT012KTA	BNT015KTA
PV input				
P _{pv} Max(W)	12000	15000	18000	22500
V _{max} PV (Vdc) (absolute Max.)	750	750	750	750
I _{sc} PV (absolute Max.) (A)	30+48	48 x 2	48 x 2	48 x2
Number MPP trackers	2	2	2	2
Number input strings	1/2	2/2	2/2	2/2
Max. PV input current (A)	20+32	32x 2	32x 2	32x 2
MPPT voltage range (Vdc)	150-600	150-600	150-600	150-600
Vdc range @ full power (Vdc)	200-600	200-600	250-600	300-600
AC Grid (output)				
Normal AC Voltage (VAC)	3P+PE/3P 133/230			
Frequency (Hz)	50			
Normal AC Current (A)	20.1	25.1	30.1	37.6
Max. cont. output current (A)	27	30	32	40
Normal Power (W)	8000	10000	12000	15000
Rated Apparent Power (VA)	8000	10000	12000	15000
Max. cont. Power (W)	8000	10000	12000	15000
Max. cont. Apparent Power (VA)	8000	10000	12000	15000
Power factor(adjustable)	1.0(-0.8~ +0.8)			
Others				
Protective class	Class I			
Ingress protection (IP)	IP65			
Temperature (°C)	-25°C to +60°C (Derating 45°C)			
Inverter Isolation	Non-isolated			
Overvoltage category	OVC III (AC Main), OVC II (PV)			
Software version	DSP:V06 CPLD:V06 HMI:V06			

This Attestation is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Attestation. Only the Client is authorized to permit copying or distribution of this Attestation.. The observations and test/inspection results referenced in this Attestation are relevant only to the sample tested/inspected. This Attestation by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program. This Attestation is not accredited under a ISO IEC 17065 accreditation.

APPENDIX: Attestation of Conformity

Ratings & Principle Characteristics:

Specifications table				
Model	BNT003KTL	BNT004KTL	BNT005KTL	BNT006KTL
PV input				
P _{pv} Max(W)	5100	6000	7500	9000
V _{max} PV (Vdc) (absolute Max.)	1100	1100	1100	1100
I _{sc} PV (absolute Max.) (A)	25 x 2	25 x 2	25 x 2	25 x 2
Number MPP trackers	2	2	2	2
Number input strings	1/1	1/1	1/1	1/1
Max. PV input current (A)	15 x 2	15 x 2	15 x 2	15 x 2
MPPT voltage range (Vdc)	150-1000	150-1000	150-1000	150-1000
Vdc range @ full power (Vdc)	200-850	200-850	200-850	250-850
AC Grid (output)				
Normal AC Voltage (VAC)	3P+N+PE/3P+PE 230/400			
Frequency (Hz)	50			
Normal AC Current (A)	4.4	5.8	7.3	8.7
Max. cont. output current (A)	5.3	7	8.5	10.5
Normal Power (W)	3000	4000	5000	6000
Rated Apparent Power (VA)	3000	4000	5000	6000
Max. cont. Power (W)	3000	4000	5000	6000
Max. cont. Apparent Power (VA)	3000	4000	5000	6000
Power factor(adjustable)	1.0(-0.8~ +0.8)			
Others				
Protective class	Class I			
Ingress protection (IP)	IP65			
Temperature (°C)	-25°C to +60°C (Derating 45°C)			
Inverter Isolation	Non-isolated			
Overvoltage category	OVC III (AC Main), OVC II (PV)			
Software version	DSP:V06 CPLD:V06 HMI:V06			

This Attestation is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Attestation. Only the Client is authorized to permit copying or distribution of this Attestation.. The observations and test/inspection results referenced in this Attestation are relevant only to the sample tested/inspected. This Attestation by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program. This Attestation is not accredited under a ISO IEC 17065 accreditation.

APPENDIX: Attestation of Conformity

Ratings & Principle Characteristics:

Specifications table				
Model	BNT008KTL	BNT010KTL	BNT012KTL	BNT013KTL
PV input				
P _{pv} Max(W)	12000	15000	18000	19500
V _{max} PV (Vdc) (absolute Max.)	1100	1100	1100	1100
I _{sc} PV (absolute Max.) (A)	25 x 2	25 x 2	25 x 2	25 x 2
Number MPP trackers	2	2	2	2
Number input strings	1/1	1/1	1/1	1/1
Max. PV input current (A)	15 x 2	15 x 2	15 x 2	15 x 2
MPPT voltage range (Vdc)	150-1000	150-1000	150-1000	150-1000
Vdc range @ full power (Vdc)	300-850	500-850	500-850	500-850
AC Grid (output)				
Normal AC Voltage (VAC)	3P+N+PE/3P+PE 230/400			
Frequency (Hz)	50			
Normal AC Current (A)	11.6	14.5	17.4	18.9
Max. cont. output current (A)	13.5	17	21.5	22
Normal Power (W)	8000	10000	12000	13000
Rated Apparent Power (VA)	8000	10000	12000	13000
Max. cont. Power (W)	8000	10000	12000	13000
Max. cont. Apparent Power (VA)	8000	10000	12000	13000
Power factor(adjustable)	1.0(-0.8~ +0.8)			
Others				
Protective class	Class I			
Ingress protection (IP)	IP65			
Temperature (°C)	-25°C to +60°C (Derating 45°C)			
Inverter Isolation	Non-isolated			
Overvoltage category	OVC III (AC Main), OVC II (PV)			
Software version	DSP:V06 CPLD:V06 HMI:V06			

This Attestation is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Attestation. Only the Client is authorized to permit copying or distribution of this Attestation.. The observations and test/inspection results referenced in this Attestation are relevant only to the sample tested/inspected. This Attestation by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program. This Attestation is not accredited under a ISO IEC 17065 accreditation.

APPENDIX: Attestation of Conformity

Ratings & Principle Characteristics:

Specifications table				
Model	BNT015KTL	BNT017KTL	BNT020KTL	BNT025KTL
PV input				
P _{pv} Max(W)	22500	25500	30000	37500
V _{max} PV (Vdc) (absolute Max.)	1100	1100	1100	1100
I _{sc} PV (absolute Max.) (A)	30 + 48	48 x 2	48 x 2	48 x 2
Number MPP trackers	2	2	2	2
Number input strings	1/2	2/2	2/2	2/2
Max. PV input current (A)	20 + 32	32 x 2	32 x 2	32 x 2
MPPT voltage range (Vdc)	150-1000	150-1000	150-1000	150-1000
Vdc range @ full power (Vdc)	500-850	500-850	500-850	500-850
AC Grid (output)				
Normal AC Voltage (VAC)	3P+N+PE/3P+PE 230/400			
Frequency (Hz)	50			
Normal AC Current (A)	21.8	24.7	29	36.3
Max. cont. output current (A)	27	30	32	40
Normal Power (W)	15000	17000	20000	25000
Rated Apparent Power (VA)	15000	17000	20000	25000
Max. cont. Power (W)	15000	17000	20000	25000
Max. cont. Apparent Power (VA)	15000	17000	20000	25000
Power factor(adjustable)	1.0(-0.8~ +0.8)			
Others				
Protective class	Class I			
Ingress protection (IP)	IP65			
Temperature (°C)	-25°C to +60°C (Derating 45°C)			
Inverter Isolation	Non-isolated			
Overvoltage category	OVC III (AC Main), OVC II (PV)			
Software version	DSP:V06 CPLD:V06 HMI:V06			

This Attestation is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Attestation. Only the Client is authorized to permit copying or distribution of this Attestation.. The observations and test/inspection results referenced in this Attestation are relevant only to the sample tested/inspected. This Attestation by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program. This Attestation is not accredited under a ISO IEC 17065 accreditation.